



EMERGENCY LIGHTING SYSTEMS – GENERAL CONTRACTORS CONTACT INFORMATION

- 1.0. Design Consultants, Consultants, UCL Project Managers and Contractors please note that UCL has **Addressable Emergency Lighting Systems** installed in a large number of UCL properties.
- 1.1. Where there are existing systems or, where there is likely to be new systems to be Installed, commissioned or decommissioned during or after works; then any programming of the system is to be carried out through UCL Emergency Lighting Contractor engineers only.

Contact details are as follows:

Alpine Works Limited

Brighton House
23-25 High Street
Ewell Village
Epsom, Surrey, KT17 1SB

John Robinson

Contracts Manager

Tel: 020 8644 2014
Web: www.alpineworks.co.uk

Important – any Contractor prior to working in an area which contains an Automatic Testing Emergency Lighting System (*Advanced Electronics Ltd / Thorn, Zumtobel / Static Inverters / Central and Automatic Testing Emergency Lighting systems*) should contact the following email address to inform and seek assistance with the Emergency Lighting system within their works areas:

The UCL Emergency Lighting Maintenance Provider **Alpine Works Ltd:**

UCL-EM@alpineworks.co.uk

EXISTING PREMISES WITH ADDRESSABLE EMERGENCY LIGHTING SYSTEMS

- 2.0. Extreme care should be taken when removing addressable lighting units from areas where refurbishments or demolitions are to be undertaken, that the fittings and data cabling between light units have been considered and that appropriate engineering contingencies taken.
- 2.1. Particularly, in maintaining existing expensive fittings, but the disconnection of the existing data cable, that is likely to cause faults on the addressable emergency lighting control panel. If in doubt, contact the **Alpine Works Ltd for advice.**